

# VILLAGE OF ROCKVILLE CENTRE

ONE COLLEGE PLACE, P.O. BOX 950

ROCKVILLE CENTRE, N.Y. 11571-0950



FRANCIS X. MURRAY, MAYOR  
KATHLEEN BAXLEY, TRUSTEE  
EMILIO F. GRILLO, TRUSTEE  
KATIE CONLON, TRUSTEE  
GREGORY P. SHAUGHNESSY, TRUSTEE

PURCHASING DEPARTMENT

516/678-9213

Wire and Cable Bid  
Bid No. 2403E1(1106)

2/29/2024

## Addendum #1

In response to questions asked of the Village:

- 1) Is this a one-time shipment, or wire to be ordered over, say, a year?

**Answer: Wire to be ordered over the year.**

- 2) The notes section of the bid specifications omitted item #16.

**Answer: The description for Item 16 should be... The 1/c – 4/0 copper conductor will consist of 19 wires stranded, type THHN/THWN-2 and rated for 600 volts. The cabled shall be rated for wet/dry Locations with a normal temperature rating of 90degrees C as per the latest edition of the National Electric Code (NEC) UL 1063 and 758, ASTM B3, B8 and ICEA S-95-658/NEMA WC70 standards.**

- 3) What is the desired put-up length and packaging (reel vs spool)?

**Answer: The spools should be 500 feet in length.**

- 4) Regarding the bid for wire – is that to include installation? Or is it for the wire only?

**Answer: No Installation, Wire Only**

- 5) Please provide clarifications for the following ...

Item #5 - 1/c 1,000 MCM 15KV covered conductor

(1. Is this a tape shield, concentric neutral or flat strap construction?)

**Answer: Tape**

Item #12 - 3/c 3/0 AWG, 15KV shielded copper wire

(1. Is this under 1 JKT? 2. Is this paralleled? 3. Is this triplexed?)

**Answer: 1 JKT**

Item #13 - 3/c 3/0 AWG, 5KV shielded copper wire

(1. Is this under 1 JKT? 2. Is this paralleled? 3. Is this triplexed?)

**Answer: 1 JKT**

Item #15 - 3/c 4/0 AWG, 15KV shielded copper wire

(1. Is this under 1 JKT? 2. Is this paralleled? 3. Is this triplexed?)

**Answer: 1 JKT**

END OF ADDENDUM NO. 1

**Please Return this signed Addendum with your Bid Response**

Company: \_\_\_\_\_

Signature: \_\_\_\_\_ Date: \_\_\_\_\_