

VILLAGE OF ROCKVILLE CENTRE

ONE COLLEGE PLACE, P.O. BOX 950 ROCKVILLE CENTRE, N.Y. 11571-0950

FRANCIS X. MURRAY, MAYOR
KATHLEEN BAXLEY, TRUSTEE
EMILIO F. GRILLO, TRUSTEE
KATIE CONLON, TRUSTEE
GREGORY P. SHAUGHNESSY, TRUSTEE



PURCHASING DEPARTMENT

516/678-9213

Supervisory Control and Data Acquisition
Bid No. 2404E2(1109)

4/11/2024

Addendum #1

In response to questions asked of the Village:

1) Do you have any drawings for this project?

Answer: Once the bid is awarded, the bidder will be asked to sign an NDA, a meeting will be scheduled and drawings will be provided.

2) Is installation required, or just equipment?

Answer: Installation is required.

3) For the bid deposit, can you confirm a Bank Check equal to 5% of Bid Item 1 meets the requirement and not 5% of the total of Items 1,2 and 3?

Answer: The bid deposit can be for 5% of total base bid (Item #1) only.

4) Excerpt in Question: SCADA Software: Commercially available SCADA package compatible with Windows platform. Acceptable software packages include:

- o Wonderware by AVEVA:
- o Ignition by Inductive Automation
- o GE Digital iFIX
- o Siemens WinCC
- o Rockwell Automation FactoryTalk View
- o Schneider Electric Vijeo Citect

Answer: Any bidder is not limited to the list of acceptable software packages in the bid package: however, the proposed SCADA package must be compatible with Windows platform.

5) Do you have a designated area for the SCADA workstations and server(s)?

Answer: The Main server is in the Power Plant and the Backup server is in an adjacent building.

6) What's your current SCADA system?

Answer: ACS – Automated Control Systems

7) Which PLC system are you using?

Answer: Linux - RedHat

8) What type of communication protocol are you using (closed red, Ethernet, fiber, etc.)?

Answer: DNP3

END OF ADDENDUM NO. 1

Please Return this signed Addendum with your Bid Response

Company: _____

Signature: _____ Date: _____