

VILLAGE OF ROCKVILLE CENTRE

ONE COLLEGE PLACE, P.O. BOX 950

ROCKVILLE CENTRE, N.Y. 11571-0950



FRANCIS X. MURRAY, MAYOR
KATHLEEN BAXLEY, TRUSTEE
MICHAEL SEPE, TRUSTEE
EMILIO F. GRILLO, TRUSTEE
KATIE CONLON - TRUSTEE

PURCHASING DEPARTMENT

516/678-9213
FAX # 516-678-9306

4/13/2023

2023 Park Lane Drainage Upgrades

Bid No. 2304CP2(1069)

Addendum No. 1

Questions asked of the Village:

- #1 - Are there any pavement cores ? is there base concrete beneath the asphalt surface course?
- #2 - With reference to the " Drainage leaching pool with top slab " detail , upper left on drawing sheet # 3 , the note says " footing ring , optional " . Please clarify .

Answers:

- #1- no cores or borings were taken. It is assumed there this is a concrete road with an asphalt overlay, which has been typical for the roads in this area.**
- #2-The footing is optional. The village may decide to have the contractor install a footing if we hit unstable material as we install the first ring. Typically a footing is not used.**

End of Addendum No. 1

Please return this signed Addendum with your bid response.

Company: _____

Signature: _____

Date: _____