

VILLAGE OF ROCKVILLE CENTRE

ONE COLLEGE PLACE, P.O. BOX 950

ROCKVILLE CENTRE, N.Y. 11571-0950



FRANCIS X. MURRAY, MAYOR
KATHLEEN BAXLEY, TRUSTEE
EMILIO F. GRILLO, TRUSTEE
KATIE CONLON, TRUSTEE
GREGORY P. SHAUGHNESSY, TRUSTEE

PURCHASING DEPARTMENT

516/678-9213
FAX # 516-678-9306

November 6, 2023

MR. B's ALL-INCLUSIVE PLAYGROUND AND VETERAN'S PARK TENNIS COURT REHABILITATION

Bid No. 2311CP2(1094)

Addendum No. 1

In response to questions asked of the Village:

1. There is no item for asphalt paving of tennis court.
2. There is no electrical plan to show connection to field house (10 pull boxes in bid).
3. There is no spec for the up-lights for the flag pole
4. There are no electrical specification in the project manual for conductors, etc.
5. The site plan indicates the entire playground area to receive poured in place safety surface(23,000 SF), but the Kompan playground plan indicates dark blue and light blue safety surface (15,310 SF) areas and turf (sod?) safety surface areas (7,250 SF), separated with flush curb. Please clarify.

Answers :

1. I concur attached is revised bid schedule.
2. Item-16E-1 (Pull Box adjustments) Item is for casting adjustments to new grade only.
3. Contractor is to provide cut sheets for up lighting to be used and approved by Village.
4. Any electrical work (flagpole light and automatic gates) is to be done as per the NYS Electrical code and is to be done by a Village licensed electrician. Cut sheets are to be provided for Village approval.
5. The entire playground area will be poured in place safety surface. **No turf** will be used. An updated design schematic will be provided by Kompan. Please use the quantity stated in the bid schedule.

End of Addendum No. 1

Please return this signed Addendum with your bid response.

Company: _____

Signature: _____

Date: _____