

VILLAGE OF ROCKVILLE CENTRE

ONE COLLEGE PLACE, P.O. BOX 950

ROCKVILLE CENTRE, N.Y. 11571-0950



FRANCIS X. MURRAY, MAYOR
KATHLEEN BAXLEY, TRUSTEE
EMILIO F. GRILLO, TRUSTEE
KATIE CONLON, TRUSTEE
GREGORY P. SHAUGHNESSY, TRUSTEE

PURCHASING DEPARTMENT

516/678-9213

12/8/2023

Basketball and Handball Court Rehabilitation @ Veteran's Park

Bid No. 2312CP1(1096)

Addendum No. 1

CLARIFICATION:

The proposed concrete sidewalk will be 6" thick with reinforcement.

In response to questions asked of the Village:

- 1- The bid sheets specify the steel railing as black steel but do not specify if there will be any colored coating upon installation. Will there be any colored steel coating?

Answer: 3'-0" high Steel railings for stairway to be coated black as stated.

- 2- The bid sheets specify the manufacturer of the basketball hoops (Douglas) but not the model. Which Douglas model from the bid sheets is acceptable?

Answer: Basketball hoops are to be manufactured by Douglas Model 646 Max (Item 69672) w/ 655 Clear Max 42" X 60" Backboard. (or approved equal).

End of Addendum No. 1

Please return this signed Addendum with your bid response.

Company: _____

Signature: _____

Date: _____