

VILLAGE OF ROCKVILLE CENTRE

ONE COLLEGE PLACE, P.O. BOX 950

ROCKVILLE CENTRE, N.Y. 11571-0950

FRANCIS X. MURRAY, MAYOR
KATHLEEN BAXLEY, TRUSTEE
EMILIO F. GRILLO, TRUSTEE
KATIE CONLON – TRUSTEE
GREGORY P. SHAUGHNESS, TRUSTEE



PURCHASING DEPARTMENT

516/678-9213

2/8/2024
Installation

Firemen's Field House Roof

Addendum No. 1

In response to questions asked of the Village:

1. On the power beam ridge it says it's 16 inches high but it doesn't say the width your choices are 3 1/2 ,5 1/2 etc.

Answer: The Power beam size should be a 5-1/2" X 16".

End of Addendum No. 1

Please return this signed Addendum with your bid response.

Company: _____

Signature: _____

Date: _____