

Inc. Village of Rockville Centre

CBS MODIFICATIONS AT PLANT No. 1

**** ADDENDUM NO. 2 ****
SEPTEMBER 29, 2023

H2M PROJECT NO.: ROCK2301

BID DATE: OCTOBER 12, 2023 @ 11:00 A.M. (CHANGE)

DESCRIPTION: VARIOUS

CLARIFICATIONS, MODIFICATIONS & ADDITIONS

1. **BID DATE:** In response to recent RFI correspondence and to allow bid holders sufficient time to generate proposal amounts, it's been decided to extend the bid period to October 12, 2023 at 11:00 a.m.
2. **SPECIFICATION 463312.23 :** Specification 463312.23 *Sodium Hydroxide Treatment System* has been amended to include the Village preferred chemical dosage pump with associated accessories and technical data. **The total amount of chemical dosage pumps needed are now four (4).**
3. **SPECIFICATION 402324:** Specification 402324 *Valves and Valve Accessories* has been amended to include the torque rating and setting range of the 8" Auma Valve Actuators.
4. **PROPOSAL ITEM 23:** Proposal Item 23 *Miscellaneous Electrical* has been amended to include the furnishment and installment of the electrical heaters.
5. **SPECIFICATION 409123.36:** Specification 263217 *Fuel Oil Tank Overfill And Leakage Alarms* has been replaced with Specification 409123.36 *Chemical Tank Gauging And Alarm System*.
6. **D201.00:** Drawing D201.00 *Basement Small Piping Plan* now denotes the installation of two (2) new pressure sustaining control valves.
7. **A100.00:** Drawing A100.00 *First Floor Restoration* now denotes direction on maintaining 4 light switches.