

EXISTING 8" VALVE AND MAIN TO BE ABANDONED. PLUG AND CAP AS REQUIRED. CONTRACTOR TO INSTALL AND CONNECT NEW 8" VALVE AND SECTION OF 8" CEMENT LINED DUCTILE IRON MAIN. CONNECT TO EXISTING 8" W/REDUCER (ALL INCLUDED IN ITEM #1 (1))

NEW LOCATION: PROVIDE NEW MUELLER HYDRANT & LATERAL W/ 8" GATE VALVE. CONTRACTOR TO PROVIDE 8"X6" TEE AS REQUIRED (N.S.P.I.); SEE DETAIL SHEET

CONNECT NEW 8" MAIN TO EXISTING MAIN W/ REDUCER

EXISTING 8" SEWER MAIN TO REMAIN (8'-0"+ INVERT)

EXISTING 8" SEWER MAIN TO REMAIN (5'-0"+ INVERT)

421'-0"+/- TO NEXT FIRE HYDRANT SOUTH ON RIVERSIDE DRIVE
427'-0"+/- TO NEXT FIRE HYDRANT ON RIVERSIDE DRIVE

CONTRACTOR TO PROVIDE ALL CLEARANCES AS PER N.C.H.D. REQUIREMENTS. SEE NOTE #23 SHEET #1 AND DETAIL SHEET #8. TYPICAL SEWER INVERT=5'-1"+ TOP OF WATER MAIN =6'-0" TO 6'-8" INVERT OF NEW MAIN =7'-2" TO 7'-9" DRAINAGE INVERT=4'-8"+ (SEE DETAIL THIS SHEET)

PROVIDE AND INSTALL NEW 14" VALVE. CONTRACTOR TO PROVIDE AND INSTALL NEW 14" X 8" X 14" TEE W/ NEW SECTION OF 14" MAIN (ITEM #1 (2A)), NEW 8" MAIN AND EXISTING 14" WATER MAIN. REMOVE EXISTING SECTION OF 6" MAIN AND TEE

CONTRACTOR IS TO OPEN ROADWAY AS PER NASSAU COUNTY'S REQUIREMENTS AND SPECIFICATION. PRIOR TO OPENING ROADWAY CONTRACTOR IS TO FILE ALL NECESSARY PAPERWORK AND SUBMIT COUNTY PERMIT TO THE VILLAGE. ALL COUNTY FILING AN FEE'S ARE TO BE INCLUDED WITHIN THE COUNTY ALLOWANCE PROVIDED IN THIS CONTRACT. PAVEMENT RESTORATION TO BE INCLUDED IN EACH CORRESPONDING ITEMS. NO SEPARATE ITEM (N.S.P.I.) FOR SAW CUTTING IN THIS CONTRACT

NOTE:

- CONTRACTOR TO PROVIDE ALL CLEARANCES TO SEWER MAINS AND DRAINAGE PIPES AS PER N.C.H.D. REQUIREMENTS. SEE NOTE #23; SHEET #1 AND DETAIL SHEET #8
- CONTRACTOR TO PROVIDE SHORING AS NECESSARY AT S. PARK AVE. (INCLUDED IN SHORING ITEM IN CONTRACT)

EXISTING 14" VALVE TO BE REPLACED. CONTRACTOR TO INSTALL AND CONNECT NEW 14" X 8" X 14" TEE ITEM #1(2A))

RELOCATE TO SOUTH SIDE OF PARK AVENUE

NEW 8" WATER VALVE (INCLUDED IN ITEM #1(1)); (TYPICAL OF 2) (1) ON NORTH SIDE OF PARK AVE. AND (1) ON SOUTH SIDE

PROVIDE NEW 1" COPPER SERVICE AND CURB VALVE (TYPICAL) ITEM #2 (1)

EXISTING WATER SERVICE FROM CURB VALVE TO DWELLING TO REMAIN (TYPICAL)

NEW LOCATION AS SHOWN.
TYPICAL HYDRANT ASSEMBLY (SHEET # 8)

