

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA

PARAMETERS (mg/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1A N-08216 ⁽¹⁾		WELL NO. 1B N-08217 ⁽¹⁾		WELL NO. 2A N-09792 ⁽¹⁾		WELL NO. 2B N-05193		WELL NO. 2C N-06817 ⁽¹⁾	
			MAX. RESULT (raw/treated)	AVG. RESULT (raw/treated)	MAX. RESULT (raw/treated)	AVG. RESULT (raw/treated)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
INORGANIC												
ARSENIC	10.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		2.1	2.1
BARIUM	2.0 mg/l	0.2 mg/l	0.0057	0.0057	0.0054	0.0054	0.004	0.004			0.0034	0.0034
CADMIUM	5.0 ug/l	5.0 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
CHROMIUM	0.10 mg/l	0.01 mg/l	ND	ND	ND	ND	ND	ND			ND	ND
COPPER	[1.3] mg/l	0.02 mg/l	0.071	0.071	ND	ND	ND	ND			ND	ND
FLUORIDE	2.2 mg/l	0.1 mg/l	ND	ND	ND	ND	ND	ND			ND	ND
LEAD	[15.0] ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
MERCURY	2.0 ug/l	0.2 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
LANGLIER SATURATION INDEX	None	None	-6.10	-6.10	-4.63	-4.63	-6.93	-6.93			-5.16	-5.16
SELENIUM	50 ug/l	5.0 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
SILVER	0.1 mg/l	0.01 mg/l	ND	ND	ND	ND	ND	ND			ND	ND
SODIUM	**20/270 mg/l	0.2 mg/l	9.0	9.0	8.4	8.4	5.1	5.1			4.3	4.3
ZINC	5.0 mg/l	0.02 mg/l	0.063	0.063	ND	ND	ND	ND			ND	ND
COLOR	15 Units	5 Units	ND	ND	ND	ND	ND	ND			ND	ND
TURBIDITY	5 Units	1 Unit	ND	ND	ND	ND	ND	ND			1.6	1.6
ODOR	3 Units	0 Units	ND	ND	ND	ND	ND	ND			2.0	2.0
IRON	0.3 mg/l	0.02 mg/l	***2.3 ⁽¹³⁾ /0.29 ^(R)	***1.7/0.06	***9.2 ⁽¹³⁾ /0.029 ^(R)	***3.0/0.06	***0.92	***0.92			***12.5	***12.5
MANGANESE	0.3 mg/l	0.01 mg/l	0.026 ⁽¹³⁾	0.023	0.23 ⁽¹³⁾	0.05	0.03	0.03			0.13	0.13
AMMONIA	None	0.1 mg/l	ND	ND	ND	ND	ND	ND			ND	ND
NITRITE	1.0 mg/l	0.1 mg/l	ND	ND	ND	ND	ND	ND			ND	ND
NITRATE	10.0 mg/l	0.1 mg/l	ND	ND	0.061 ⁽²⁾	0.061	ND	ND			ND	ND
CHLORIDE	250 mg/l	1.0 mg/l	14.1	14.1	11.9	11.9	6.7	6.7			6.0	6.0
TOTAL HARDNESS	None	1.0 mg/l	11.5	11.5	10.4	10.4	5.6	5.6			5.6	5.6
TOTAL ALKALINITY	None	0 mg/l	1.0	1.0	15.8	15.8	ND	ND			9.6	9.6
pH (BEFORE TREATMENT)	None	None	6.0 ⁽²⁾	5.6	6.0 ⁽²⁾	5.8	6.0 ⁽²⁾	5.4			6.0 ⁽²⁾	5.8
TOTAL DISSOLVED SOLIDS	None	5.0 mg/l	58.0	58.0	56.0	56.0	46.0	46.0			39.0	39.0
DETERGENTS (MBAS)	None	0.08 mg/l	ND	ND	ND	ND	ND	ND			ND	ND
SULFATE	250 mg/l	5.0 mg/l	23.7	23.7	11.1	11.1	13.9	13.9			7.1	7.1
FREE CYANIDE	200 ug/l	10.0 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
ANTIMONY	6.0 ug/l	5.9 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
BERYLLIUM	4.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
CALCIUM	None	1.0 mg/l	2.2	2.2	2.0	2.0	1.0	1.0			1.0	1.0
MAGNESIUM	None	1.0 mg/l	1.4	1.4	1.3	1.3	0.74	0.74			0.73	0.73
NICKEL	0.1 mg/l	0.0005 mg/l	0.0061	0.0061	0.0058	0.0058	0.0024	0.0024			0.00053	0.00053
THALLIUM	2.0 ug/l	0.3 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
PERCHLORATE	18 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND			ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

** - 20 mg/l IS THE LIMIT FOR PEOPLE ON HIGHLY RESTRICTED SODIUM DIETS AND 270 mg/l FOR THOSE ON MODERATELY RESTRICTED SODIUM DIETS

*** - EXCEEDS NEW YORK STATE/USEPA LIMITS FOR POTABLE WATER

[] - USEPA/NYS/DH ACTION LEVEL

WELL NO. 2B - OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA (continued)

PARAMETERS (mg/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3A N-05194 ⁽¹⁾		WELL NO. 3B N-05195 ⁽¹⁾		WELL NO. 4A N-00072 ⁽¹⁾		WELL NO. 4B N-03745 ⁽¹⁾		WELL NO. 4C N-08218 ⁽¹⁾	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
INORGANIC												
ARSENIC	10.0 ug/l	3.0 ug/l	1.4	1.4	ND	ND	ND	ND	ND	ND	ND	ND
BARIUM	2.0 mg/l	0.2 mg/l	ND	ND	ND	ND	ND	ND	0.0022	0.0022	0.0063	0.0063
CADMIUM	5.0 ug/l	5.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CHROMIUM	0.10 mg/l	0.01 mg/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
COPPER	[1.3] mg/l	0.02 mg/l	0.015	0.015	0.030	0.030	0.045	0.045	0.034	0.034	0.051	0.051
FLUORIDE	2.2 mg/l	0.1 mg/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
LEAD	[15.0] ug/l	1.0 ug/l	ND	ND	1.8	1.8	ND	ND	1.9	1.9	1.8	1.8
MERCURY	2.0 ug/l	0.2 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
LANGLIER SATURATION INDEX	None	None	-5.97	-5.97	-7.42	-7.42	-6.21	-6.21	-7.07	-7.07	-6.51	-6.51
SELENIUM	50 ug/l	5.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
SILVER	0.1 mg/l	0.01 mg/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
SODIUM	**20/270 mg/l	0.2 mg/l	4.5	4.5	4.8	4.8	5.4	5.4	6.2	6.2	11.7	11.7
ZINC	5.0 mg/l	0.02 mg/l	0.072	0.072	0.028	0.028	0.050	0.050	0.076	0.076	0.090	0.090
COLOR	15 Units	5 Units	ND	ND	ND	ND	5.0	5.0	ND	ND	ND	ND
TURBIDITY	5 Units	1 Unit	11.4	11.4	ND	ND	6.1	6.1	1.3	1.3	ND	ND
ODOR	3 Units	0 Units	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
IRON	0.3 mg/l	0.02 mg/l	***9.5	***9.5	0.16	0.16	***0.39	***0.39	***0.65	***0.65	***2.2	***2.2
MANGANESE	0.3 mg/l	0.01 mg/l	0.12	0.12	0.012	0.012	ND	ND	ND	ND	0.036	0.036
AMMONIA	None	0.1 mg/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
NITRITE	1.0 mg/l	0.1 mg/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
NITRATE	10.0 mg/l	0.1 mg/l	0.066 ⁽²⁾	0.066	ND	ND	ND	ND	ND	ND	ND	ND
CHLORIDE	250 mg/l	1.0 mg/l	5.7	5.7	6.1	6.1	7.8	7.8	8.1	8.1	30.9	30.9
TOTAL HARDNESS	None	1.0 mg/l	4.1	4.1	2.6	2.6	7.0	7.0	5.4	5.4	21.9	21.9
TOTAL ALKALINITY	None	0 mg/l	8.9	8.9	ND	ND	2.6	2.6	ND	ND	ND	ND
pH (BEFORE TREATMENT)	None	None	7.0 ⁽²⁾	5.9	6.0 ⁽²⁾	5.4	6.0 ⁽²⁾	5.4	6.0 ⁽²⁾	5.3	6.0 ⁽²⁾	5.3
TOTAL DISSOLVED SOLIDS	None	5.0 mg/l	33.0	33.0	24.0	24.0	39.0	39.0	36.0	36.0	82.0	82.0
DETERGENTS (MBAS)	None	0.08 mg/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
SULFATE	250 mg/l	5.0 mg/l	ND	ND	ND	ND	ND	ND	6.9	6.9	14.3	14.3
FREE CYANIDE	200 ug/l	10.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ANTIMONY	6.0 ug/l	5.9 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BERYLLIUM	4.0 ug/l	3.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CALCIUM	None	1.0 mg/l	1.0	1.0	0.4	0.4	1.7	1.7	0.9	0.9	4.2	4.2
MAGNESIUM	None	1.0 mg/l	0.4	0.4	0.4	0.4	0.69	0.69	0.8	0.8	2.8	2.8
NICKEL	0.1 mg/l	0.0005 mg/l	0.00053	0.00053	0.0019	0.0019	0.0047	0.0047	0.0035	0.0035	0.0083	0.0083
THALLIUM	2.0 ug/l	0.3 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
PERCHLORATE	18 ug/l	1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

CONT - CONTAMINANT

ND - NOT DETECTED

** - 20 mg/l IS THE LIMIT FOR PEOPLE ON HIGHLY RESTRICTED SODIUM DIETS AND 270 mg/l FOR THOSE ON MODERATELY RESTRICTED SODIUM DIETS

*** - EXCEEDS NEW YORK STATE/USEPA LIMITS FOR POTABLE WATER

[] - USEPA/NYS/SDH ACTION LEVEL

⁽¹⁾ - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1A N-08216		WELL NO. 1B N-08217		WELL NO. 2A N-09792		WELL NO. 2B N-05193		WELL NO. 2C N-06817	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
SYNTHETIC ORGANICS CONTAMINANTS (SOC)												
LINDANE	0.2 ug/l	0.025 ug/l	NOT TESTED		NOT TESTED		NOT TESTED		OUT OF SERVICE		NOT TESTED	
HEPTACHLOR	0.4 ug/l	0.025 ug/l										
ALDRIN	5.0 ug/l	0.025 ug/l										
HEPTACHLOR EPOXIDE	0.2 ug/l	0.025 ug/l										
DIELDRIN	2.0 ug/l	0.05 ug/l										
ENDRIN	2.0 ug/l	0.05 ug/l										
METHOXYCHLOR	40.0 ug/l	0.25 ug/l										
TOXAPHENE	3.0 ug/l	2.5 ug/l										
CHLORDANE	2.0 ug/l	0.5 ug/l										
TOTAL PCBs	0.5 ug/l	0.5 ug/l										
PROPACHLOR	50.0 ug/l	1.0 ug/l										
ALACHLOR	2.0 ug/l	1.0 ug/l										
SIMAZINE	4.0 ug/l	0.5 ug/l										
ATRAZINE	3.0 ug/l	0.5 ug/l										
METOLACHLOR	50.0 ug/l	1.0 ug/l										
METRIBUZIN	50.0 ug/l	0.5 ug/l										
BUTACHLOR	50.0 ug/l	1.0 ug/l										

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 2B - OUT OF SERVICE

NOT TESTED - STATE AND COUNTY TESTING REQUIREMENTS INCLUDE TESTING FOR SOC ONCE EVERY 18 MONTHS. THIS WELL NOT TESTED IN 2018.

1 - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3A N-05194		WELL NO. 3B N-05195		WELL NO. 4A N-00072		WELL NO. 4B N-03745		WELL NO. 4C N-08218 ⁽¹⁾	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
SYNTHETIC ORGANICS CONTAMINANTS (SOC)												
LINDANE	0.2 ug/l	0.025 ug/l	NOT TESTED		NOT TESTED		NOT TESTED		NOT TESTED		ND	ND
HEPTACHLOR	0.4 ug/l	0.025 ug/l									ND	ND
ALDRIN	5.0 ug/l	0.025 ug/l									ND	ND
HEPTACHLOR EPOXIDE	0.2 ug/l	0.025 ug/l									ND	ND
DIELDRIN	2.0 ug/l	0.05 ug/l									ND	ND
ENDRIN	2.0 ug/l	0.05 ug/l									ND	ND
METHOXYCHLOR	40.0 ug/l	0.25 ug/l									ND	ND
TOXAPHENE	3.0 ug/l	2.5 ug/l									ND	ND
CHLORDANE	2.0 ug/l	0.5 ug/l									ND	ND
TOTAL PCBs	0.5 ug/l	0.5 ug/l									ND	ND
PROPACHLOR	50.0 ug/l	1.0 ug/l									ND	ND
ALACHLOR	2.0 ug/l	1.0 ug/l									ND	ND
SIMAZINE	4.0 ug/l	0.5 ug/l									ND	ND
ATRAZINE	3.0 ug/l	0.5 ug/l									ND	ND
METOLACHLOR	50.0 ug/l	1.0 ug/l									ND	ND
METRIBUZIN	50.0 ug/l	0.5 ug/l									ND	ND
BUTACHLOR	50.0 ug/l	1.0 ug/l									ND	ND

CONT - CONTAMINANT

ND - NOT DETECTED

NOT TESTED - STATE AND COUNTY TESTING REQUIREMENTS INCLUDE TESTING FOR SOC ONCE EVERY 18 MONTHS THIS WELL NOT TESTED IN 2018.

4 - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1A N-08216		WELL NO. 1B N-08217		WELL NO. 2A N-09792		WELL NO. 2B N-05193		WELL NO. 2C N-06817	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
SYNTHETIC ORGANICS CONTAMINANTS (SOC)												
(CONT'D.)												
2,4-D	50.0 ug/l	0.25 ug/l	NOT	TESTED	NOT	TESTED	NOT	TESTED	OUT OF	SERVICE	NOT	TESTED
2,4,5-TP (SILVEX)	10.0 ug/l	0.13 ug/l										
DINOSEB	7.0 ug/l	0.2 ug/l										
DALAPON	200 ug/l	0.7 ug/l										
PICLORAM	500 ug/l	0.6 ug/l										
DICAMBA	50.0 ug/l	0.08 ug/l										
PENTACHLOROPHENOL	1.0 ug/l	0.2 ug/l										
HEXACHLOROCYCLOPENTADIENE	50.0 ug/l	0.64 ug/l										
bis(2-ETHYLHEXYL)ADIPATE	400 ug/l	1.0 ug/l										
bis(2-ETHYLHEXYL)PHTHALATE	6.0 ug/l	3.0 ug/l										
HEXACHLOROENZENE	1.0 ug/l	0.25 ug/l										
BENZO(A)PYRENE	0.2 ug/l	0.1 ug/l										
ALDICARB SULFONE	2.0 ug/l	1.0 ug/l										
ALDICARBSULFOXIDE	4.0 ug/l	1.0 ug/l										
ALDICARB	3.0 ug/l	1.0 ug/l										
TOTAL ALDICARBS	7.0 ug/l	1.0 ug/l										
OXAMYL	200 ug/l	1.0 ug/l										
METHOMYL	50.0 ug/l	1.0 ug/l										
3-HYDROXYCARBOFURAN	50.0 ug/l	1.0 ug/l										
CARBOFURAN	40.0 ug/l	1.0 ug/l										
CARBARYL	50.0 ug/l	1.0 ug/l										
GLYPHOSATE	700 ug/l	10.0 ug/l										
DIQUAT	20 ug/l	1.0 ug/l										
ENDOTHALL	100 ug/l	50.0 ug/l										
1,2-DIBROMOETHANE (EDB)	0.05 ug/l	0.02 ug/l										
1,2-DIBROMO-3-CHL.PROPANE	0.2 ug/l	0.02 ug/l										
DIOXIN	30 Pg/L	5.0 Pg/L										

CONT. - CONTAMINANT

ND - NOT DETECTED

Pg/L - PICOGRAMS PER LITER

WELL NO. 2B - OUT OF SERVICE

1 - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3A N-05194		WELL NO. 3B N-05195		WELL NO. 4A N-00072		WELL NO. 4B N-03745		WELL NO. 4C N-08218 ⁽¹⁾	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
SYNTHETIC ORGANICS CONTAMINANTS (SOC)												
(CONT'D.)												
2,4-D	50.0 ug/l	0.25 ug/l	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED	ND	ND
2,4,5-TP (SILVEX)	10.0 ug/l	0.13 ug/l									ND	ND
DINOSEB	7.0 ug/l	0.2 ug/l									ND	ND
DALAPON	200 ug/l	0.7 ug/l									ND	ND
PICLORAM	500 ug/l	0.6 ug/l									ND	ND
DICAMBA	50.0 ug/l	0.08 ug/l									ND	ND
PENTACHLOROPHENOL	1.0 ug/l	0.2 ug/l									ND	ND
HEXACHLOROCYCLOPENTADIENE	50.0 ug/l	0.64 ug/l									ND	ND
bis(2-ETHYLHEXYL)ADIPATE	400 ug/l	1.0 ug/l									ND	ND
bis(2-ETHYLHEXYL)PHTHALATE	6.0 ug/l	3.0 ug/l									ND	ND
HEXACHLOROBENZENE	1.0 ug/l	0.25 ug/l									ND	ND
BENZO(A)PYRENE	0.2 ug/l	0.1 ug/l									ND	ND
ALDICARB SULFONE	2.0 ug/l	1.0 ug/l									ND	ND
ALDICARBSULFOXIDE	4.0 ug/l	1.0 ug/l									ND	ND
ALDICARB	3.0 ug/l	1.0 ug/l									ND	ND
TOTAL ALDICARBS	7.0 ug/l	1.0 ug/l									ND	ND
OXAMYL	200 ug/l	1.0 ug/l									ND	ND
METHOMYL	50.0 ug/l	1.0 ug/l									ND	ND
3-HYDROXYCARBOFURAN	50.0 ug/l	1.0 ug/l									ND	ND
CARBOFURAN	40.0 ug/l	1.0 ug/l									ND	ND
CARBARYL	50.0 ug/l	1.0 ug/l									ND	ND
GLYPHOSATE	700 ug/l	10.0 ug/l									ND	ND
DIQUAT	20 ug/l	1.0 ug/l									ND	ND
ENDOTHALL	100 ug/l	50.0 ug/l									ND	ND
1,2-DIBROMOETHANE (EDB)	0.05 ug/l	0.02 ug/l									ND	ND
1,2-DIBROMO-3-CHL.PROPANE	0.2 ug/l	0.02 ug/l									ND	ND
DIOXIN	30 Pg/L	5.0 Pg/L									ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

Pg/L - PICOGRAMS PER LITER

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1A N-08216 ⁽⁴⁾		WELL NO. 1B N-08217 ⁽⁴⁾		WELL NO. 2A N-09792 ⁽⁴⁾		WELL NO. 2B N-05193		WELL NO. 2C N-06817 ⁽¹⁾	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
TRihalOMETHANES AND HALOACETIC ACIDS												
CHLOROACETIC ACID	---	< 2.0 ug/l							OUT OF SERVICE			
BROMOACETIC ACID	---	< 1.0 ug/l	NOT TESTED		NOT TESTED		NOT TESTED				NOT TESTED	
DICHLOROACETIC ACID	---	< 1.0 ug/l	NOT TESTED		NOT TESTED		NOT TESTED				NOT TESTED	
TRICHLOROACETIC ACID	---	< 1.0 ug/l	NOT TESTED		NOT TESTED		NOT TESTED				NOT TESTED	
DIBROMOACETIC ACID	---	< 2.0 ug/l	NOT TESTED		NOT TESTED		NOT TESTED				NOT TESTED	
TOTAL HALOACETIC ACID	60 ug/l	< 2.0 ug/l	NOT TESTED		NOT TESTED		NOT TESTED				NOT TESTED	
CHLOROFORM	50 ug/l	< 0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
BROMODICHLOROMETHANE	50 ug/l	< 0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
DIBROMOCHLOROMETHANE	50 ug/l	< 0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
BROMOFORM	50 ug/l	< 0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
TOTAL TRIHALOMETHANES	80 ug/l	< 1.0 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
RADIONUCLIDES												
GROSS ALPHA	15 pCi/L	< 3 pCi/L	NOT TESTED		NOT TESTED		NOT TESTED				NOT TESTED	
GROSS BETA	50 pCi/L	< 3 pCi/L	NOT TESTED		NOT TESTED		NOT TESTED				NOT TESTED	
RADIUM 226 & 228 COMBINED	6 pCi/L	< 3 pCi/L	NOT TESTED		NOT TESTED		NOT TESTED				NOT TESTED	
TOTAL URANIUM	30 ug/l	< 3.0 ug/l	NOT TESTED		NOT TESTED		NOT TESTED				NOT TESTED	

CONT - CONTAMINANT

ND - NOT DETECTED

Pg/L - PICOGRAMS PER LITER

pCi/L - pico Curies per Liter

WELL NO. 2B - OUT OF SERVICE

⁽¹⁾ - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3A N-05194 ⁽⁴⁾		WELL NO. 3B N-05195 ⁽⁴⁾		WELL NO. 4A N-00072 ⁽⁴⁾		WELL NO. 4B N-03745 ⁽⁴⁾		WELL NO. 4C N-08218 ⁽⁴⁾	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
TRihalOMETHANES AND HALOACETIC ACIDS												
CHLOROACETIC ACID	---	< 2.0 ug/l										
BROMOACETIC ACID	---	< 1.0 ug/l	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED
DICHLOROACETIC ACID	---	< 1.0 ug/l	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED
TRICHLOROACETIC ACID	---	< 1.0 ug/l	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED
DIBROMOACETIC ACID	---	< 2.0 ug/l	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED
TOTAL HALOACETIC ACID	60 ug/l	< 2.0 ug/l	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED
CHLOROFORM	50 ug/l	< 0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BROMODICHLOROMETHANE	50 ug/l	< 0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
DIBROMOCHLOROMETHANE	50 ug/l	< 0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BROMOFORM	50 ug/l	< 0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TOTAL TRIHALOMETHANES	80 ug/l	< 1.0 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
RADIONUCLIDES												
GROSS ALPHA	15 pCi/L	< 3 pCi/L	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED
GROSS BETA	50 pCi/L	< 3 pCi/L	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED
RADIUM 226 & 228 COMBINED	6 pCi/L	< 3 pCi/L	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED
TOTAL URANIUM	30 ug/l	< 3.0 ug/l	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED	NOT	TESTED

CONT. - CONTAMINANT

ND - NOT DETECTED

Pg/L - PICOGRAMS PER LITER

pCi/L - pico Curies per Liter

(4) - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1A N-08216		WELL NO. 1B N-08217		WELL NO. 2A N-09792		WELL NO. 2B N-05193		WELL NO. 2C N-06817	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
<u>UCMR3</u>												
1,4 DIOXANE	50 ug/l	0.7 ug/l										
<u>VOLATILES</u>												
1,1-DICHLOROETHANE	5.0 ug/l	0.03 ug/l										
1,2,3-TRICHLORPROPANE	5.0 ug/l	0.03 ug/l										
1,3-BUTADIENE	50 ug/l	0.1 ug/l										
BROMOCHLOROMETHANE	50 ug/l	0.08 ug/l										
BROMOMETHANE	5.0 ug/l	0.2 ug/l										
CHLORODIFLUOROMETHANE	5.0 ug/l	0.08 ug/l										
CHLOROMETHANE	5.0 ug/l	0.2 ug/l										
<u>PERFLUORO-CHEMICALS</u>												
PERFLUOROBUTANESULFONIC ACID	5.0 ug/l	0.9 ug/l										
PERFLUOROHEPTANOIC ACID	5.0 ug/l	0.01 ug/l										
PERFLUOROHEXANESULFONIC ACID	5.0 ug/l	0.03 ug/l										
PERFLUORONONANOIC ACID	5.0 ug/l	0.02 ug/l										
PERFLUORO-OCTANESULFONIC ACID	5.0 ug/l	0.04 ug/l										
PERFLUORO-OCTANOIC ACID	5.0 ug/l	0.02 ug/l										
<u>METALS</u>												
CHROMIUM	100 ug/l	0.2 ug/l										
COBALT		1.0 ug/l										
MOLYBDENUM		1.0 ug/l										
STRONTIUM		0.3 ug/l										
VANADIUM		0.2 ug/l										
HEXAVALENT CHROMIUM CHLORATE		0.03 ug/l 20 ug/l										
<u>HORMONES</u>												
17-ALPHA-ETHINYLESTRADIOL	50 ug/l	0.0004 ug/l										
17-BETA-ESTRADIOL	50 ug/l	0.0009 ug/l										
4-ANDROSTENE-3,17-DIONE	50 ug/l	0.0003 ug/l										
EQUILIN	50 ug/l	0.004 ug/l										
ESTRIOL	50 ug/l	0.0008 ug/l										
ESTRONE	50 ug/l	0.002 ug/l										
TESTOSTERONE	50 ug/l	0.0001 ug/l										

ND - NOT DETECTED

WELL NOS. 1, 5-1 AND 5-2 ARE OUT OF SERVICE

() - NUMBER OF SAMPLES COLLECTED AND TESTING DURING YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3A N-05194		WELL NO. 3B N-05195		WELL NO. 4A N-00072		WELL NO. 4B N-03745		WELL NO. 4C N-08218 ⁽¹⁾	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
UCMR3												
1,4 DIOXANE	50 ug/l	0.7 ug/l										
VOLATILES												
1,1-DICHLOROETHANE	5.0 ug/l	0.03 ug/l										
1,2,3-TRICHLORPROPANE	5.0 ug/l	0.03 ug/l										
1,3-BUTADIENE	50 ug/l	0.1 ug/l										
BROMOCHLOROMETHANE	50 ug/l	0.06 ug/l										
BROMOMETHANE	5.0 ug/l	0.2 ug/l										
CHLORODIFLUOROMETHANE	5.0 ug/l	0.08 ug/l										
CHLOROMETHANE	5.0 ug/l	0.2 ug/l										
PERFLUORO-CHEMICALS												
PERFLUOROBUTANESULFONIC ACID	5.0 ug/l	0.9 ug/l										
PERFLUOROHEPTANOIC ACID	5.0 ug/l	0.01 ug/l										
PERFLUOROHXANESULFONIC ACID	5.0 ug/l	0.03 ug/l										
PERFLUORONONANOIC ACID	5.0 ug/l	0.02 ug/l										
PERFLUOROOCTANESULFONIC ACID	5.0 ug/l	0.04 ug/l										
PERFLUOROOCTANOIC ACID	5.0 ug/l	0.02 ug/l										
METALS												
CHROMIUM	100 ug/l	0.2 ug/l										
COBALT		1.0 ug/l										
MOLYBDENUM		1.0 ug/l										
STRONTIUM		0.3 ug/l										
VANADIUM		0.2 ug/l										
HEXAVALENT CHROMIUM CHLORATE		0.03 ug/l 20 ug/l										
HORMONES												
17-ALPHA-ETHNYLESTRADIOL	50 ug/l	0.0004 ug/l										
17-BETA-ESTRADIOL	50 ug/l	0.0009 ug/l										
4-ANDROSTENE-3,17-DIONE	50 ug/l	0.0003 ug/l										
EQUILIN	50 ug/l	0.004 ug/l										
ESTRIOL	50 ug/l	0.0008 ug/l										
ESTRONE	50 ug/l	0.002 ug/l										
TESTOSTERONE	50 ug/l	0.0001 ug/l										

ND - NOT DETECTED

(1) - NUMBER OF SAMPLES COLLECTED AND TESTING DURING YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1A N-08216 ⁽⁴⁾		WELL NO. 1B N-08217 ⁽⁴⁾		WELL NO. 2A N-09792 ⁽⁴⁾		WELL NO. 2B N-05193		WELL NO. 2C N-06817 ⁽¹⁾	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
VOLATILE ORGANICS												
DICHLORODIFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
CHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
VINYL CHLORIDE	2.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
BROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
CHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
TRICHLOROFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
1,1-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
METHYLENE CHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
TRANS-1,2-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
1,1-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
cis-1,2 DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
2,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
BROMOCHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
1,1,1-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
CARBON TETRACHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
1,1-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
1,2-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
TRICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
1,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
DIBROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
TRANS-1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
cis-1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
1,1,2-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
TETRACHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 2B - OUT OF SERVICE

⁽⁴⁾ - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1A N-08216 ⁽⁴⁾		WELL NO. 1B N-08217 ⁽⁴⁾		WELL NO. 2A N-09792 ⁽⁴⁾		WELL NO. 2B N-05193		WELL NO. 2C N-06817 ⁽¹⁾	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
VOLATILE ORGANICS (CONT'D.)												
1,3-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
CHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
1,1,1,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
BROMOBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
1,1,2,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
1,2,3-TRICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
2-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
4-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
1,2-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
1,3-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
1,4-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
1,2,4-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
HEXACHLOROBUTADIENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
1,2,3-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
BENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
TOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
ETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
M,P-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
O-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
STYRENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
ISOPROPYLBENZENE (CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
N-PROPYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND
1,3,5-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND			ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

WELL NO. 2B - OUT OF SERVICE

⁽¹⁾ - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 1A N-08216 ⁽⁴⁾		WELL NO. 1B N-08217 ⁽⁴⁾		WELL NO. 2A N-09792 ⁽⁴⁾		WELL NO. 2B N-05193		WELL NO. 2C N-06817 ⁽¹⁾	
			MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
VOLATILE ORGANICS (CONT'D.)												
TERT-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
1,2,4-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
SEC-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
4-ISOPROPYLTOLUENE (P-CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
N-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND
METHYL TERT.BUTYL ETHER (MTBE)	10.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	OUT OF SERVICE		ND	ND

CONT - CONTAMINANT

ND - NOT DETECTED

WELL NO 2B - OUT OF SERVICE

⁽¹⁾ - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3A N-05194 ⁽⁶⁾		WELL NO. 3B N-05195 ⁽⁴⁾		WELL NO. 4A N-00072 ⁽⁴⁾		WELL NO. 4B N-03745 ⁽⁶⁾		WELL NO. 4C N-08218 ⁽⁴⁾	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
VOLATILE ORGANICS												
DICHLORODIFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
VINYL CHLORIDE	2.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TRICHLOROFLUOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
METHYLENE CHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TRANS-1,2-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
<i>cis</i> -1,2-DICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
2,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BROMOCHLOROMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CARBON TETRACHLORIDE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-DICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TRICHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
DIBROMOMETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TRANS-1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
<i>cis</i> -1,3-DICHLOROPROPENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2-TRICHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TETRACHLOROETHENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

CONT - CONTAMINANT

ND - NOT DETECTED

() - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3A N-05194 ⁽¹⁾		WELL NO. 3B N-05195 ⁽¹⁾		WELL NO. 4A N-00072 ⁽¹⁾		WELL NO. 4B N-03745 ⁽¹⁾		WELL NO. 4C N-08218 ⁽¹⁾	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
VOLATILE ORGANICS (CONT'D.)												
1,3-DICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
CHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,1,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BROMOBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,1,2,2-TETRACHLOROETHANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,3-TRICHLOROPROPANE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
2-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
4-CHLOROTOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,3-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,4-DICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
HEXACHLOROBUTADIENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,3-TRICHLOROBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
BENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
TOLUENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
M,P-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
O-XYLENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
STYRENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
ISOPROPYLBENZENE (CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
N-PROPYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,3,5-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

CONT - CONTAMINANT

ND - NOT DETECTED

⁽¹⁾ - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR

INC. VILLAGE OF ROCKVILLE CENTRE - WATER DEPT.
2018 WATER QUALITY DATA (continued)

PARAMETERS (ug/l)	MAX. CONT. LEVEL	DETECT. LIMITS	WELL NO. 3A N-05194 ⁽⁴⁾		WELL NO. 3B N-05195 ⁽⁴⁾		WELL NO. 4A N-00072 ⁽⁴⁾		WELL NO. 4B N-03745 ⁽⁴⁾		WELL NO. 4C N-08218 ⁽⁴⁾	
			MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT (Raw/Treat)	AVG. RESULT (Raw/Treat)	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT	MAX. RESULT	AVG. RESULT
VOLATILE ORGANICS (CONT'D.)												
TERT-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
1,2,4-TRIMETHYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
SEC-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
4-ISOPROPYLTOLUENE (P-CUMENE)	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
N-BUTYLBENZENE	5.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND
METHYL TERT.BUTYL ETHER (MTBE)	10.0 ug/l	0.5 ug/l	ND	ND	ND	ND	ND	ND	ND	ND	ND	ND

CONT. - CONTAMINANT

ND - NOT DETECTED

⁽⁴⁾ - NUMBER OF SAMPLES COLLECTED AND TESTED DURING THE YEAR